



Public Spa Specification Sheet

Owner's Name/Address (DBA) _____
 City _____ Phone No. _____
 Contractor's Name/Address _____
 City _____ Phone No. _____
 Pool Location/Address _____ City _____

_____ Plot Plan - Shows all existing and proposed facilities including spa enclosure
 _____ Scale (1/2" = 1 ft) - Plan and profile drawings _____ Mechanical equipment and plumbing lay-out plan
 _____ Approved restrooms, showers and drinking fountain if any dwelling units over 300 ft from spa
 Spa Capacity _____ Gallons Surface area _____ sq. ft.
 No. of skimmers _____ Make _____ Model _____ Proper Equalizers _____ Anti-entrapment cover _____
 Number of return lines _____ Type of pipe: PVC Sch 40 _____ Copper _____ Pipe size at head _____
 Pump: Make _____ Model _____ Hp _____ Gpm @ 60 ft TDH _____
 Filter Type and Size: D.E. @ 2 gal/min/sq. ft. _____
 Sand @ High rate - 15 gal/min/sq. ft. _____ Make _____
 @ Rapid rate - 3 gal/min/sq. ft. _____ Model _____
 Separation Tank: Make _____ Model _____ Dry well size _____ ft x _____ ft Diam _____ ft
 Backwash via legal air gap _____ Site glass _____ Sewer _____ Dry well _____
 Spa Construction: Gunite _____ Other _____ Color: _____
 Chlorinator: Make _____ Model _____
 Flow Meter: Make _____ Model _____ Influent and effluent pressure gauges _____
 Hand hold around entire perimeter: Bullnose _____ Other _____ All corners covered _____
 Split main drains _____ Anti-entrapment covers _____ All Spa safety signs _____ Body hook & pole _____
 Life ring & rope _____ Proper steps _____ Proper ladders, recessed steps, grab rails _____ Proper hand
 rails _____ Depth markers _____ Deck drainage _____ Unobstructed non-slip walkways 4 ft wide around 50%
 of spa perimeter _____ All pools at least 6 ft apart _____ Water supply and fill line from approved source and
 approved back flow preventer _____ Approved test kit _____ Underwater light _____ All valves and controls
 identified _____ A 5 ft high fence around spa with self-closing, self-latching gates, gates must open outwards _____
 Openings in fence must not exceed 4" wide and 2" at bottom _____ Contrasting tile for step and bench _____
 Spa emergency shutoff switch _____

Additional requirements: _____

